

# SMART THREE PHASE METER

## AM370.MV

Medium Voltage Applications



### INTRODUCTION

The AM370 electricity meter series are modern, electronic, fully programmable devices, designed for application in AMI systems for monitoring and control of electricity consumption.

The AM370 electricity meter series meet remote data transmission requirements and enable readouts of various measurands. The meters are compliant with IEC and DLMS/COSEM standards and have been designed to serve billing purposes. AM370.MV, is four wires, compact electronic meter (indirect connection meter for CT and VT operation), with accuracy class 0.2 for active energy and 1 for reactive energy, capable of measuring Active and reactive Energy. It could work for 2CT or 3CT systems. It is type approved according to IEC & EN standards. This makes it perfectly suitable Medium Voltage Applications.

The indirect connection meter is used to measure energy consumption in 57.7 or 63.5 VAC, 50 Hz, and 1-6 Ampere, three-phase four wires power net. It contains an independent measuring element allowing consumed energy to be measured. The external CT ratio is stored in the meter to calculate the primary values based on the secondary values.

There is a LED mounted on the front panel of the meter, pulsing at a rate of 10000

pulses per kWh or KVAR for energy registration.

The modular nature of the meter means that its communications interface supports a broad range of field-upgradable communications options including GPRS/4G, and RF among others.

### STANDARDS

- IEC 62052-11
- IEC 62053-23:2003
- EN 50470
- IEC 695-2-1
- IEC62055
- IEC 62056-42
- IEC 62056-46
- IEC 62056-53
- IEC 62056-61
- IEC 60068



## METER SPECIFICATIONS

### Electrical Characteristics

Nominal Voltage (Vn)	3x 57.7/100 V and 3x63.5/110 V
Voltage Variation (Min)	-40% Vn
Voltage Variation (Max)	30% Vn
Nominal Current (Ibase)	1 A
Maximum Current (I <sub>max</sub> )	6 A
Nominal Frequency	50 Hz
Frequency Variations	±5%
Accuracy Class	0.2 Active 1 Reactive
Starting Current	0.2 % I <sub>b</sub>
Power Consumption	≤ 2W
Measurements	KWh, kVarh, V, I, PF, P, Q, MD (KW)
Back-up Battery Type	Lithium Battery
Back-up Battery Lifetime	15 Years

### Memory

Type	Flash memory
Retention Period	More than 20 Years

### Environmental Conditions

IP Rating	IP54
Temperature Range	-25°C to +70°C
Storage Temperature	-40°C to +80°C
Humidity Range	<95%
Altitude	0-3600M
Service Life	20 Years

### Communication

Optical Interface	Standard Optical Port (IEC 62056-21) Complies with DLMS/COSEM HDLC mode-E protocol
-------------------	---

AMI/AMM Module	Supported using: <ul style="list-style-type: none"> <li>• LTE modem</li> <li>• RF Modem</li> </ul>
----------------	--

Data Transmission Rate	Optical Port: 9600 bit/s LTE: 10 Mbit/s RF: 50 - 2400 Kbit/s
------------------------	--

### Mechanical

Dimensions	Height x Width x Depth 260 x 170 x 88.5 mm
Weight	1.1 Kg

## METER FEATURES

### Feature Description

Display	<ul style="list-style-type: none"> <li>• Fully electronic (LCD) with backlight</li> </ul>
Load Profile	<ul style="list-style-type: none"> <li>• Load profile divided on two profiles: <ul style="list-style-type: none"> <li>✓ Load profile (for energy)</li> <li>✓ Load profile (for measurement value) <ul style="list-style-type: none"> <li>- Including voltage, current, demand</li> </ul> </li> <li>✓ Load profile (for demand of MV consumers)</li> </ul> </li> </ul>
Events	<ul style="list-style-type: none"> <li>• The AMx70 records a considerable amount of data for extended periods of time</li> <li>• In addition, the AMx70 stores above to 375 events</li> <li>• Events are logged with a date/time stamp</li> </ul>
Firmware upgrade	<ul style="list-style-type: none"> <li>• Ability to easily update / change the meter firmware without processing it on-site. This is done locally via optical port and remotely in a massive change command from the Management Software</li> <li>• The meter support firmware image. can be scheduled to be performed immediately or at a future date performed immediately or at a future date.</li> <li>• The meter will perform a self-check process after the execution of the new firmware update, and the result of the self-check process will be stored on the meter event log (and will be retrievable locally or remotely)</li> </ul>
Tamper Proofing	<ul style="list-style-type: none"> <li>• The AMx70 can detect the following types of tamper attempts: <ul style="list-style-type: none"> <li>✓ Meter Cover Open</li> <li>✓ Terminal Cover Open</li> <li>✓ Reverse Connection</li> <li>✓ Overload</li> <li>✓ Over Voltage</li> <li>✓ Under Voltage</li> </ul> </li> </ul>
Alarms	<ul style="list-style-type: none"> <li>• The meter supports alarm detection and with LED notification and icons on the LCD</li> <li>• The meter can be configured to give any combination of alarms as required</li> </ul>
Test mode	<ul style="list-style-type: none"> <li>• The meter supports a Test Mode in which there will be an automated test sequence available that includes: <ul style="list-style-type: none"> <li>✓ Full diagnostic test; testing all of the active and inactive functionality</li> </ul> </li> <li>• Metering accuracy test: enabled to allow for accuracy testing to be performed without affecting the recorded customer registration of energy</li> </ul>
Auto diagnostics	<ul style="list-style-type: none"> <li>• With firmware update, the meter well diagnoses: <ul style="list-style-type: none"> <li>✓ Meter and memory integrity</li> <li>✓ Display, alarms &amp; battery status</li> </ul> </li> </ul>

### Outline drawing

